



Document / Drawing Review Status

- ☐ Proceed, no exception taken
- ☐ Proceed subject to incorporation of changes indicated. Revise & Re-Submit
- ☐ Do not proceed. Undertake changes noted and re-submit
- ☐ Review not required work may proceed

**IMPORTANT**

Acceptance with or without comments of vendor's drawing or documents shall not relieve the vendor from complying with all terms, conditions, codes, standard & requirements of order & specification. Re-submit when a revision is made to the drawing or document by the manufacture or by sub-sequent.

Sign:

By:

Date \_\_\_\_\_

NOTE :

1. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.
2. ALL WELDED JOINTS SHALL BE SUBJECTED TO NON-DESTRUCTIVE TESTING (NDT) IN ACCORDANCE WITH APPLICABLE CODES AND STANDARDS
3. THE PAINTING/COATING SYSTEM SHALL BE IN ACCORDANCE WITH PROJECT SPECIFICATION ADIP-3655-2100-018-SFP-0003-2. ALL SURFACE PREPARATION, COATING MATERIALS, APPLICATION METHODS, AND INSPECTION REQUIREMENTS SHALL STRICTLY COMPLY WITH THIS SPECIFICATION.

4	-12	GASKET	NON ASBESTOS	2			14.5	
	-11	HEX BOLT/H.N	ASTM A193 Gr.B7/ ASTM A194 Gr.2H	8			M19x100L	
	-10	WIRE MESH SCREEN	304 S.S	1			0.9x4 MESH	
	-9	PLATE FLANGE	ASTM A36	2			112	
	-8	ELBOW (90° S.R)	ASTM A36	2			4" SCH.40	
	-7	NOZZLE NECK	ASTM A106 Gr.B	1			4" SCH.40	
	-6	FLANGE	ASTM A105	1			4" ASME #150 S.O.R.F	B
	-5	STUD BOLT/H.N	ASTM A193 Gr.B7/ ASTM A194 Gr.2H	8			5/8"-11UNCx100L	
	-4	GASKET	NON ASBESTOS	1			14.5 ASME #150 R.F	
	-3	REIND. PAD	ASTM A36	1			16	
	-2	NOZZLE NECK	ASTM A106 Gr.B	1			4" SCH.40	B
	-1	FLANGE	ASTM A105	1			4" ASME #150 S.O.R.F	
	-3	REIND. PAD	ASTM A36	1			16	
	-2	NOZZLE NECK	ASTM A106 Gr.B	1			3" SCH.40	
	-1	FLANGE	ASTM A105	1			3" ASME #150 S.O.R.F	
	3	-3	REIND. PAD	ASTM A36	1			16
-2		NOZZLE NECK	ASTM A106 Gr.B	1			3" SCH.40	
-1		FLANGE	ASTM A105	1			3" ASME #150 S.O.R.F	
2	-3	REIND. PAD	ASTM A36	1			16	
	-2	NOZZLE NECK	ASTM A106 Gr.B	1			3" SCH.40	
	-1	FLANGE	ASTM A105	1			3" ASME #150 S.O.R.F	
1	-3	REIND. PAD	ASTM A36	1			16	
	-2	NOZZLE NECK	ASTM A106 Gr.B	1			3" SCH.40	
	-1	FLANGE	ASTM A105	1			3" ASME #150 S.O.R.F	
ITEM NO.	NAME OF PART		MATERIAL	QTY	CONST & 2 YEARS COMM'L OPER.	UNIT (EA)	REMARKS	
PART CODE								

( 1 ) SET TO BE MANUFACTURED

REVISIONS											
B	04/05/26		ISSUED FOR APPROVAL		INK	HER	DS	HK	MS	-	
A	26/02/26		ISSUED FOR APPROVAL		INK	HER	DS	HK	MS	-	
REV	DATE		DESCRIPTION		DRN	CKD	DESIGN ENG	LEAD ENG	PROJ APP	CLIENT APP	



	NAME	DATE
DRAWN	INKO	26/02/26
CHECKED	-	-
DESIGN ENG	-	-
LEAD ENG	-	-
PROJ APP'D	-	-
CLIENT	-	-



PT.HANAZONO ENGINEERING INDONESIA

L2, 38 RICHARDSON ST WEST PERTH,  
WESTERN AUSTRALIA 6005  
+61 8 9432 0100  
[www.comoeng.com.au](http://www.comoeng.com.au)

ESIA	TITLE POBOYO 2000 TPD EXPANSION PROJECT FILTER PRESS AREA CLEAN WATER TANK (4800-TK-122) DETAIL OF ROOF NOZZLE
------	--

PLOT SCALE	AS-SHOWN
------------	----------

NEITHER THIS DOCUMENT NOR ITS  
CONTENTS MAY BE USED OR © COPYRIGHT  
REPRODUCED IN ANY MANNER  
WITHOUT WRITTEN AUTHORIZATION.

CLIENT NUM HNZ-V-PT006108-4800-STR-DWG-510		AT SHEET	
PROJ NUM E2602		SHT: 1 OF 1	
MARK NUM -	DRG NUM E2602-4800-DWG-510		REV B