

OBJECT

Strength Calculation for Filter Feed Tank
Poboya 2000tpd Expansion Project
Client Doc Number : [HNZ-V-PT0061.08-4820-STR-CAL-004](#)

REFERENCES

3655.15-61.08-4000-F-BOD-001 Process Design Criteria
3655.15-61.08-4000-F-CAL-001 Mass Balance



B	Issued for Approval	08/05/2026	Wawan	Ardiyanto	Muraasto	
A	Issued for Review	06/04/2026	Wawan	Ardiyanto	Muraasto	
Revision	Description	Date	Prepared By	Reviewed By	Approved	Client App
CLIENT PT Citra Palu Mineral		TITLE Strength Calculation for Filter Feed Tank				REV B
PROJECT Poboya 2000tpd Expansion Project		PT. COMO ENGINEERS		PROJECT No. E2602		
BY Wawan	DATE 08/05/2026	CHECKED Ardiyanto	DATE 08/05/2026	Doc No E2602-4820-CAL-401		

Revision No. : B

Page 2 of 20


Revision History

[illegible]

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 3 of 20

CONTENTS

Description	Page
1. Introduction.....	4
2. Support Document	4
3. Code and Reference	4
4. Design	4
5. Conclusion	19
6. Anchor Bolt Design	21

COMO ENGINEERS	POBOYA 2000 TPD EXPANSION PROJECT	 PT Citra Palu Minerals
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 4 of 20

1. Introduction

This document consist of additional analysis for tank thickness. The dimension is 9.3 m height and 8.5 m for the diameter. Additional analysis needed to calculate the strength of shell tank to resist equipment (agitator) load that located on top of the tank.

2. Support Document

- MC5925_02- Filter Feed Tank Agitator

3. Code and Reference

Code and reference that used for this calculation listed below :

- API STD 650 2018 – Welded Tanks for Oil Storage
- SNI 1729:2020 – Spesifikasi untuk Bangunan Gedung Baja Struktural


4. Design

4.1 Isometric Model



Analysis design for the tank use STAAD Pro software. Tank model picture showed below :

A 3D perspective view of a cylindrical storage tank with a conical roof. The tank is divided into several horizontal sections, each color-coded: the top roof section is grey, the upper cylindrical section is blue, and the lower cylindrical section is green. A network of structural stiffeners is visible, including longitudinal ribs and circumferential rings. Elevation markers are placed along the right side of the tank, indicating heights of 1.200, 3.600, 5.250, 7.050, 8.050, and 9.300 meters. The base of the tank is supported by a series of vertical legs or skirts.

Material			
PLATE			
Shell elev.(m)	Main Thickness (mm)	Corrosion Allowance (mm)	Design Thickness (mm)
0 - 3.6	9	3	12
3.6 - 7.2	7	3	10
7.2 - 9.3	5	3	8
STIFFENER			
Profile elev. (m)	Type		
1.6	L.130.130.12		
3.45	L.130.130.12		
5.25	L.130.130.12		
7.05	L.130.130.12		
8.05	L.130.130.12		
9.3	L.200.200.25		
PLATFORM SUPPORT			
Profile elev. (m)	Type		
9.3	Half.Tee.300.300.10.15		



Picture 1. Tank Model and Properties

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 5 of 20


4.2 Load and Combination

4.2.1 Daad Load

Unit weight of steel used as calculation is 78.5 kN/m³.

4.2.2 Hidrostatic Load

Hidrostatic load is pressure load from fluida content. Specific gravity fluida is 1.82 Ton/m³



Hidrostatic load : $1.82 \times 9.3 = 16.93 \text{ Ton/m}^2 \rightarrow 166.04 \text{ kN/m}^2$

4.2.3 Agitator and Platform Load

- Point load to represent platform load taken from document : 3655.15 - Joint Reactions Platform on Top of CIL Tanks (4 support)

AGITATOR LOAD


Mixer Mass	23.77 kN
Bend. Moment	29.091 kNm
Torque	34.529 kNm
Axial Load	34.975 kN

Point Load 2

Load on model as follows :

Mixer Mass	17.83 kN
Bend. Moment	21.82 kNm
Torque	25.90 kNm
Axial Load	26.23 kN

TANK LOADS	
LOADS: FACTORED	
MIXER MASS (kg)	2377
BEND. MOMENT (Nm)	29091
TORQUE (Nm)	34529
AXIAL LOAD (N)	34975

COMO ENGINEERS	POBOYA 2000 TPD EXPANSION PROJECT	 PT. Citra Palu Minerals
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 6 of 20

GRATING

Length = 9.8 m
 Wide = 3 m

 q area = 0.45 kPa


 Input Load
 q line = **0.675** kN/m

Live Load On Agitator Platform



Length = 9.8 m
 Wide = 3 m

 q area = 5 kPa

Load on Model :
 q line = **7.5** kN/m



Picture 2. Agitator Input Load

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 7 of 20

4.2.4 Seismic Load

Seismic load calculated based on API 650.

- The seismic overturning moment at the base of the tank shell shall be the SRSS summation of the impulsive and convective components multiplied by the respective moment arms to the center of action of the forces unless otherwise specified.

Ringwall Moment, M_{rw} :

$$M_{rw} = \sqrt{[A_i(W_i X_i + W_s X_s + W_r X_r)]^2 + [A_c(W_c X_c)]^2} \quad (\text{E.6.1.5-1})$$

Equation Ai :

Impulsive spectral acceleration parameter, A_i :

$$A_i = S_{DS} \left(\frac{I}{R_{wi}} \right) = 2.5 Q F_a S_0 \left(\frac{I}{R_{wi}} \right) \quad (\text{E.4.6.1-1})$$

$$\text{However, } A_i \geq 0.007 \quad (\text{E.4.6.1-2})$$

$$\text{and, for } S_1 \geq 0.6:$$

$$A_i \geq 0.5 S_1 \left(\frac{I}{R_{wi}} \right) = 0.625 S_p \left(\frac{I}{R_{wi}} \right) \quad (\text{E.4.6.1-3})$$

$$I = 1 \text{ (category II)}$$

$$S_{ds} = 0.806$$

$$R_{wi} = 3.5$$

Table E.4—Response Modification Factors for ASD Methods

Anchorage system	R_{wi} (impulsive)	R_{wc} (convective)
Self-anchored	3.5	2
Mechanically-anchored	4	2

$$A_i = 0.23$$



Equation Ac

Convective spectral acceleration parameter, A_c :

$$\text{When, } T_C \leq T_L \quad A_c = K S_{D1} \left(\frac{1}{T_c} \right) \left(\frac{I}{R_{wc}} \right) = 2.5 K Q F_a S_0 \left(\frac{T_s}{T_c} \right) \left(\frac{I}{R_{wc}} \right) \leq A_i \quad (\text{E.4.6.1-4})$$

$$\text{When, } T_C > T_L \quad A_c = K S_{D1} \left(\frac{T_L}{T_c^2} \right) \left(\frac{I}{R_{wc}} \right) = 2.5 K Q F_a S_0 \left(\frac{T_s T_L}{T_c^2} \right) \left(\frac{I}{R_{wc}} \right) \leq A_i \quad (\text{E.4.6.1-5})$$



	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 8 of 20

$K_s = 0.58$



$T_c = 3.03$

$R_{wc} = 2$

$K = 1.5$

$S_{D1} = 0.582$

$A_c = 0.14$

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 9 of 20

Equation W_i and X_i :

E.6.1.1 Effective Weight of Product

The effective weights W_i and W_c shall be determined by multiplying the total product weight, W_p , by the ratios W_i/W_p and W_c/W_p , respectively, Equations E.6.1.1-1 through E.6.1.1-3.

When D/H is greater than or equal to 1.333, the effective impulsive weight is defined in Equation E.6.1.1-1:

$$W_i = \frac{\tanh\left(0.866\frac{D}{H}\right)}{0.866\frac{D}{H}} W_p \quad (\text{E.6.1.1-1})$$

When D/H is less than 1.333, the effective impulsive weight is defined in Equation E.6.1.1-2:

$$W_i = \left[1.0 - 0.218\frac{D}{H}\right] W_p \quad (\text{E.6.1.1-2})$$

When D/H is greater than or equal to 1.3333, the height X_i is determined by Equation E.6.1.2.1-1:



$$X_i = 0.375H \quad (\text{E.6.1.2.1-1})$$

When D/H is less than 1.3333, the height X_i is determined by Equation E.6.1.2.1-2:

$$X_i = \left[0.5 - 0.094\frac{D}{H}\right] H \quad (\text{E.6.1.2.1-2})$$

D	=	8.5 m
H	=	9.3 m
D/H	=	0.91
Y	=	1.82
W_p	=	9425.97 kN
perimeter	=	26.71 m
$3.67H/D$	=	4.02
W_i	=	7547.87 kN
X_i	=	3.85 m



	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 10 of 20

Equation Wc and Xc :

The effective convective weight is defined in Equation E.6.1.1-3:

$$W_c = 0.230 \frac{D}{H} \tanh\left(\frac{3.67H}{D}\right) W_p \quad (\text{E.6.1.1-3})$$

The height X_c is determined by Equation E.6.1.2.1-3:

$$X_c = \left[1.0 - \frac{\cosh\left(\frac{3.67H}{D}\right) - 1}{\frac{3.67H}{D} \sinh\left(\frac{3.67H}{D}\right)} \right] H \quad (\text{E.6.1.2.1-3})$$

$$W_c = 1545.28 \text{ kN}$$

$$X_c = 7.45 \text{ m}$$

Value of Ws and Xs :

Ws = Total weight of tank shell and appurtenances

Xs = Height from bottom of the tank shell to the shell's center of gravity

L.130.130.12

$$A = 2976 \text{ mm}^2 = 0.002976 \text{ m}^2$$

$$w = 6.24 \text{ kN}$$

$$n = 5$$

$$\text{Weight Total L.130} = 31.20 \text{ kN}$$

L.200.200.25

$$A = 9375 \text{ mm}^2 = 0.009375 \text{ m}^2$$

$$w = 19.66 \text{ kN}$$

$$n = 1$$

$$\text{Weight Total L.130} = 19.66 \text{ kN}$$

H.300.300.15.10 H.Tee



$$A = 11850 \text{ mm}^2 = 0.01185 \text{ m}^2$$

$$w = 1.16 \text{ kN}$$

$$n = 4$$

$$\text{Weight Total H.300 tee} = 4.65 \text{ kN}$$



	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 11 of 20

Shell T 12 mm

$$\begin{aligned} A &= 0.32 \text{ m}^2 \\ w &= 90.59 \text{ kN} \end{aligned}$$

Shell T 10 mm

$$\begin{aligned} A &= 0.27 \text{ m}^2 \\ w &= 75.49 \text{ kN} \end{aligned}$$

Shell T 8 mm

$$\begin{aligned} A &= 0.21 \text{ m}^2 \\ w &= 37.75 \text{ kN} \end{aligned}$$



$$\begin{aligned} \text{TOTAL WEIGHT (Ws)} &= 259.35 \text{ kN} \\ \text{H tank} &= 9.30 \text{ m} \\ \text{Xs} &= 4.65 \text{ m} \end{aligned}$$

From calculation above,

$$\begin{aligned} (A_i \cdot W_i) / \text{perimeter} &= 65.07 \text{ kN/m, at H} = 3.85 \text{ m} \\ (A_i \cdot W_s) / \text{perimeter} &= 2.24 \text{ kN/m, at H} = 4.65 \text{ m} \\ (A_c \cdot W_c) / \text{perimeter} &= 10.66 \text{ kN/m, at H} = 7.07 \text{ m} \end{aligned}$$

Simplification

$$\begin{aligned} W &= 77.96 \text{ kN/m} \\ H &= 4.31 \text{ m} \end{aligned}$$

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 12 of 20

4.2.5 Wind Load

Wind load calculated based on SNI 1727 : 2020.

4.2.6 Load Combination

Load combination based on SNI 1729 : 2020

Service load combination :

1. D
2. $D + L$
3. $D + (L_r \text{ atau } R)$
4. $D + 0,75 L + 0,75(L_r \text{ atau } R)$
5. $D + 0,6 W$
6. $D + 0,75 (0,6 W) + 0,75 L + 0,75 (L_r \text{ atau } R)$
7. $0,6D + 0,6 W$



8. $1,0D + 0,7E_v + 0,7E_h$
9. $1,0D + 0,525E_v + 0,525E_h + 0,75L$
10. $0,6D - 0,7E_v + 0,7E_h$

Ultimate load combination :

1. $1,4D$
2. $1,2 D + 1,6 L + 0,5 (L_r \text{ atau } R)$
3. $1,2D + 1,6 (L_r \text{ atau } R) + (L \text{ atau } 0,5 W)$
4. $1,2D + 1,0 W + L + 0,5(L_r \text{ atau } R)$
5. $0,9 D + 1,0 W$

6. $1,2D + E_v + E_h + L$
7. $0,9D - E_v + E_h$




	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 13 of 20


4.3 Analysis Design



4.3.1 Input Model

a. Hidrostatic Load (MAX =167 kN/m2)




b. Agitator Load






	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 14 of 20

c. Seismic Load ($W_i = 77.96 \text{ kN/m}$)




d. Wind Load (0.9 kN/m^2)




	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 15 of 20



4.3.2 Output Data




Stress Shell due Selfweight (max : 5 MPa)




Stress Shell due Platform Support (max : 7.3 MPa)



	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 16 of 20




Stress Shell due Seismic Load EQx (max : 67.9 MPa)



Stress due Windload Wx+ (max : 1.48 MPa)

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 17 of 20





Stress due Load Combination (Service) (max : 76 MPa)


Stress Summary Table

	Plate	L/C	Shear (Local)		Membrane (Local)			Bending Moment (Local)		
			SQX MPa	SQY MPa	SX MPa	SY MPa	SXY MPa	MX kN-m/m	MY kN-m/m	MX Y kN-m/m
Max Qx	326	19 201	1.537	-0.073	-1.196	0.275	-13.598	0.002	0.004	-0.294
Min Qx	335	19 201	-1.536	0.077	1.123	0.086	13.657	-0.002	-0.004	0.294
Max Qy	337	22 204	-0.042	2.659	41.845	-2.576	-0.137	-0.059	-0.146	0.008
Min Qy	337	20 202	0.044	-2.664	-41.881	2.522	-0.904	0.06	0.146	-0.008
Max Sx	88	18 103	0	-0.028	65.44	-5.52	-0.286	-0.006	-0.021	0
Min Sx	328	22 204	0.041	-2.657	-41.929	2.487	-0.924	0.06	0.144	-0.008
Max Sy	57	22 204	0	-0.034	17.637	14.798	3.768	-0.023	-0.075	-0.001
Min Sy	61	19 201	0	0.044	-21.516	-18.112	1.766	0.028	0.092	0
Max Sxy	728	20 202	-0.001	-0.003	0.025	-1.977	16.751	0.002	0.004	0.002
Min Sxy	712	21 203	0.001	0	0.013	0.314	-16.346	0	-0.001	-0.002
Max Mx	337	20 202	0.044	-2.664	-41.881	2.522	-0.904	0.06	0.146	-0.008
Min Mx	340	25 207	-0.162	2.171	64.015	-5.589	1.178	-0.088	-0.253	0.032
Max My	340	19 201	0.23	-2.632	-41.75	0.074	-2.185	0.059	0.146	-0.043
Min My	337	26 208	-0.032	2.184	64.835	-1.724	-0.368	-0.088	-0.257	0.006
Max Mxy	326	21 203	-1.535	0.073	1.137	0.138	13.74	-0.002	-0.004	0.294
Min Mxy	335	21 203	1.536	-0.073	-1.205	0.235	-13.685	0.001	0.003	-0.294





	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 18 of 20


Maximum stress Sx occurred due combination load 103 : 1.0DL + 1.0 EQ + 1LL + Hidrostatic




Stress due Combination 103 (max : 66 MPa)

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 19 of 20


All Stress ratio stiffener frame condition are under allowance (1) :



COMO ENGINEERS	POBOYA 2000 TPD EXPANSION PROJECT	 PT Citra Palu Minerals
(CPMWork No.) 14898	Project Doc. No. : E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 20 of 20



5. Conclusion

- All component, steel frame and steel shell with current configuration is capable to resist the loads.
- The configuration as follows :



Material			
PLATE			
Shell elev.(m)	Main Thickness (mm)	Corrosion Allowance (mm)	Design Thickness (mm)
0 - 3.6	9	3	12
3.6 - 7.2	7	3	10
7.2 - 9.3	5	3	8
STIFFENER			
Profile elev. (m)	Type		
1.6	L.130.130.12		
3.45	L.130.130.12		
5.25	L.130.130.12		
7.05	L.130.130.12		
8.05	L.130.130.12		
9.3	L.200.200.25		
PLATFORM SUPPORT			
Profile elev. (m)	Type		
9.3	Half.Tee.300.300.10.15		



	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No.: E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 21

Anchor Bolt Design

A-s = Installed Bolt Nominal Root Area (mm²)

A-s-r = Anchor Required Root Area (mm²)

Av = Seismic Vertical Earthquake Acceleration Coefficient (g)

Ca-anchor = Anchor Corrosion Allowance (mm)

D = Tank nominal diameter (m)

Dac = Bolt Circle Diameter (m)

Fp = Design Pressure Operating Ratio

Fty = Minimum Yield Strength of the Bottom Shell Course (MPa)

Fy = Anchor Yield Strength per API-650 Table 5.21a (MPa)

Fy-ambient = Anchor Yield Strength at Ambient Temperature per API-650 Table 5.21a (MPa)

H = Tank Height (m)

MWS = Shell Wind Overturning Moment (N.m)

Ma-anchor = Anchor Material

Mrw = Seismic Overturning Moment (N.m)

N = Anchors Quantity

N-min = Minimum Required Number of Anchors per API-650 5.12.3

OD = Tank Outer diameter (m)

P = Internal Pressure (kPa)

P-attachment = Anchor Attachment Design Load per API-650 5.12.13 and Steel Plate Engineering Data-Volume 2 Part V (N)

PWR = Roof Wind Pressure (kPa)

Pt = Test Pressure (kPa)

Sd = Allowable Anchor Stress per API-650 Table 5.21a (MPa)

Sd-shell = Allowable Shell Stress at Anchor Attachment per API-650 Table 5.21a (MPa)

Tb = Load per Anchor per API-650 5.12.2 (N)

U = Net Uplift Load per API-650 5.12.2 (N)

W1 = Corroded Weight of the Roof Plates Plus the Corroded Weight of the Shell and any Other Corroded Permanent Attachments Acting on the Shell (N)

W2 = Corroded Weight of the Shell and any Corroded Permanent Attachments Acting on the Shell Including the Portion of the Roof Plates and Framing Acting on The Shell (N)

W3 = Nominal Weight of the Roof Plates Plus the Nominal Weight of the Shell and any Other Permanent Attachments Acting on the Shell (N)

Wr-pl = Roof Plates Nominal Weight (N)

Wr-pl-corr = Roof Corroded Plates Weight (N)

Wrs-pl-corr = Roof Plates Corroded Weight Acting on The Shell (N)

Ws-framing = Shell New Framing Weight (stiffeners) (N)

Ws-framing-corr = Shell Corroded Framing Weight (stiffeners) (N)

Ws-pl = Shell Plates Nominal Weight (N)

Ws-pl-corr = Shell Corroded Plates Weight (N)

Wss = Roof Structure Nominal Weight Acting on The Shell (N)

Wss-corr = Roof Structure Corroded Weight Acting on The Shell (N)



Y-bolt = Anchor Yield Load (N)

d = Anchor Bolt Diameter (mm)

d-req = Bolt Required Diameter per ANSI B1.1 (mm)

p = Bolt Thread Pitch (mm)

position_angles = Anchors Position Angles (deg)

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No.: E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

$A_v = 0.38 \text{ g}$
 $Ca\text{-anchor} = 1.5 \text{ mm}$
 $D = 8.5 \text{ m}$
 $Dac = 8.69 \text{ m}$
 $F_p = 0.4$
 $F_{ty} = 250.0 \text{ MPa}$
 $H = 9.3 \text{ m}$
 $MWS = 114,650.6 \text{ N.m}$
 $Ma\text{-anchor} = A307-B$
 $Mrw = 8,259,828.0 \text{ N.m}$
 $N = 16$
 $OD = 8.52 \text{ m}$
 $P = 0.0 \text{ kPa}$
 $PWR = 0 \text{ kPa}$
 $P_t = 0.0 \text{ kPa}$
 $W_{r-pl} = 0.0 \text{ N}$
 $W_{r-pl-corr} = 0.0 \text{ N}$
 $W_{rs-pl-corr} = 0 \text{ N}$
 $W_{s-framing} = 15,192.95 \text{ N}$
 $W_{s-framing-corr} = 12,032.89 \text{ N}$
 $W_{s-pl} = 198,031.56 \text{ N}$
 $W_{s-pl-corr} = 140,680.87 \text{ N}$
 $W_{ss} = 78,712.88 \text{ N}$
 $W_{ss-corr} = 0.0 \text{ N}$
 $d = 48 \text{ mm}$
 $p = 5.0 \text{ mm}$
 $position_angles = [0 \ 22.5 \ 45 \ 67.5 \ 90 \ 112.5 \ 135 \ 157.5 \ 180 \ 202.5 \ 225 \ 247.5 \ 270 \ 292.5 \ 315 \ 337.5] \text{ deg}$

Anchors Spacing Requirements

Max Allowable Spacing Between Anchors at Shell Outer Diameter per API-650 5.12.3

Max Allowable Spacing ($max_allowable_spacing$) = 3 m

Actual Spacing ($actual_spacing$) = 1.67 m

$actual_spacing \leq max_allowable_spacing \Rightarrow PASS$

$N_{min} = CEILING(((\pi * OD) / 3))$

$N_{min} = CEILING(((\pi * 8.524) / 3))$

$N_{min} = 9$

$N \geq N_{min} \Rightarrow PASS$



Anchors meet spacing requirements.

Anchors Average Spacing (half the span on each side of the anchor) at Bolt Circle

Anchors are equally spaced.

Average Spacing ($average_spacing$) = 1.71 m

Bolt loads will be based on equally spaced anchors.

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No.: E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

Anchor Material Properties

Material (A307-B) = A307-B

Minimum Tensile Strength (Sut-anchor) = 415 MPa

Minimum Yield Strength (Sy-anchor) = 250 MPa

Minimum Yield Strength at Ambient Temperature (Sy-ambient-anchor) = 250 MPa

$F_y = \text{MIN}(\text{Sy-ambient-anchor}, 380)$

$F_y = \text{MIN}(250, 380)$

$F_y = 250 \text{ MPa}$

$F_{y\text{-ambient}} = \text{MIN}(\text{Sy-ambient-anchor}, 380)$

$F_{y\text{-ambient}} = \text{MIN}(250, 380)$

$F_{y\text{-ambient}} = 250 \text{ MPa}$

Uplift Load Cases per API-650 Table 5.21a

$W1 = W_{s\text{-pl-corr}} + W_{s\text{-framing-corr}} + W_{r\text{-pl-corr}}$

$W1 = 140,680.867 + 12,032.8854 + 0.0$

$W1 = 152,713.75 \text{ N}$

$W2 = W_{s\text{-pl-corr}} + W_{s\text{-framing-corr}} + W_{rs\text{-pl-corr}} + W_{ss\text{-corr}}$

$W2 = 140,680.867 + 12,032.8854 + 0 + 0.0$

$W2 = 152,713.75 \text{ NW3} = W_{s\text{-pl}} + W_{s\text{-framing}} + W_{r\text{-pl}} + W_{ss}$

$W3 = W_{s\text{-pl}} + W_{s\text{-framing}} + W_{r\text{-pl}} + W_{ss}$

$W3 = 198,031.5614 + 15,192.9471 + 0.0 + 78,712.8847$

$W3 = 291,937.39 \text{ N}$

Uplift Case 1: Design Pressure Only

$U = (P * (D^2) * 785) - W1$

$U = (0.0 * (8.5^2) * 785) - 152,713.7525$

$U = -152,713.75 \text{ (Set to 0 N since it cannot be less than 0)}$

$T_b = U / N$

$T_b = 0 / 16$

$T_b = 0 \text{ N}$

$S_d = (5 / 12) * F_y$

$S_d = (5 / 12) * 250$

$S_d = 104.17 \text{ MPa}$

$A\text{-s-r} = T_b / S_d$



$A\text{-s-r} = 0 / 104.1667$

$A\text{-s-r} = 0.0 \text{ mm}^2$

$P\text{-attachment} = 1.5 * T_b$

$P\text{-attachment} = 1.5 * 0$

$P\text{-attachment} = 0.0 \text{ N}$

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No.: E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

$Sd-shell = (2 / 3) * Fty$
 $Sd-shell = (2 / 3) * 250.0$
 $Sd-shell = 166.67 \text{ MPa}$

Uplift Case 2: Test Pressure Only

$U = (Pt * (D^2) * 785) - W3$
 $U = (0.0 * (8.5^2) * 785) - 291,937.3931$
 $U = -291,937.39 \text{ (Set to 0 N since it cannot be less than 0)}$

$Tb = U / N$
 $Tb = 0 / 16$
 $Tb = 0 \text{ N}$

$Sd = (5 / 9) * Fy\text{-ambient}$
 $Sd = (5 / 9) * 250$
 $Sd = 138.89 \text{ MPa}$

$A-s-r = Tb / Sd$
 $A-s-r = 0 / 138.8889$
 $A-s-r = 0.0 \text{ mm}^2$

$P\text{-attachment} = 1.5 * Tb$
 $P\text{-attachment} = 1.5 * 0$
 $P\text{-attachment} = 0.0 \text{ N}$

$Sd-shell = (5 / 6) * Fty$
 $Sd-shell = (5 / 6) * 250.0$
 $Sd-shell = 208.33 \text{ MPa}$



Uplift Case 3: Wind Load Only

$U = ((PWR * (D^2) * 785) + ((4 * MWS) / D)) - W2$
 $U = ((0 * (8.5^2) * 785) + ((4 * 114,650.6013) / 8.5)) - 152,713.7525$
 $U = -98,760.53 \text{ (Set to 0 N since it cannot be less than 0)}$

$Tb = U / N$
 $Tb = 0 / 16$
 $Tb = 0 \text{ N}$

$Sd = 0.8 * Fy$
 $Sd = 0.8 * 250$
 $Sd = 200.0 \text{ MPa}$

$A-s-r = Tb / Sd$
 $A-s-r = 0 / 200.0$
 $A-s-r = 0.0 \text{ mm}^2$

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No.: E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

$P_{\text{attachment}} = 1.5 * T_b$

$P_{\text{attachment}} = 1.5 * 0$

$P_{\text{attachment}} = 0.0 \text{ N}$

$S_d\text{-shell} = (5 / 6) * F_{ty}$

$S_d\text{-shell} = (5 / 6) * 250.0$

$S_d\text{-shell} = 208.33 \text{ MPa}$

Uplift Case 4: Seismic Load Only

$U = ((4 * Mr_w) / D) - (W_2 * (1 - (0.4 * A_v)))$

$U = ((4 * 8,259,828.0044) / 8.5) - (152,713.7525 * (1 - (0.4 * 0.3808)))$

$U = 3,757,525.49 \text{ N}$

$T_b = U / N$

$T_b = 3,757,525.4907 / 16$

$T_b = 234,845.34 \text{ N}$

$S_d = 0.8 * F_y$

$S_d = 0.8 * 250$

$S_d = 200.0 \text{ MPa}$

$A\text{-s-r} = T_b / S_d$

$A\text{-s-r} = 234,845.3432 / 200.0$

$A\text{-s-r} = 1,174.23 \text{ mm}^2$

$P_{\text{attachment}} = 3 * T_b$

$P_{\text{attachment}} = 3 * 234,845.3432$

$P_{\text{attachment}} = 704,536.03 \text{ N}$

$S_d\text{-shell} = (5 / 6) * F_{ty}$

$S_d\text{-shell} = (5 / 6) * 250.0$

$S_d\text{-shell} = 208.33 \text{ MPa}$

Uplift Case 5: Design Pressure + Wind Load

$U = (((F_p * P) + PWR) * (D^2) * 785) + ((4 * MWS) / D) - W_1$

$U = (((0.4 * 0.0) + 0) * (8.5^2) * 785) + ((4 * 114,650.6013) / 8.5) - 152,713.7525$

$U = -98,760.53 \text{ (Set to } 0 \text{ N since it cannot be less than } 0)$

$T_b = U / N$



$T_b = 0 / 16$

$T_b = 0 \text{ N}$

$S_d = (5 / 9) * F_y$

$S_d = (5 / 9) * 250$

$S_d = 138.89 \text{ MPa}$

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No.: E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

$$A-s-r = T_b / S_d$$

$$A-s-r = 0 / 138.8889$$

$$A-s-r = 0.0 \text{ mm}^2$$

$$P\text{-attachment} = 1.5 * T_b$$

$$P\text{-attachment} = 1.5 * 0$$

$$P\text{-attachment} = 0.0 \text{ N}$$

$$S_d\text{-shell} = (5 / 6) * F_{ty}$$

$$S_d\text{-shell} = (5 / 6) * 250.0$$

$$S_d\text{-shell} = 208.33 \text{ MPa}$$

Uplift Case 6: Design Pressure + Seismic Load

$$U = ((F_p * P * (D^2) * 785) + ((4 * M_{rw}) / D)) - (W_1 * (1 - (0.4 * A_v)))$$

$$U = ((0.4 * 0.0 * (8.5^2) * 785) + ((4 * 8,259,828.0044) / 8.5)) - (152,713.7525 * (1 - (0.4 * 0.3808)))$$

$$U = 3,757,525.49 \text{ N}$$

$$T_b = U / N$$

$$T_b = 3,757,525.4907 / 16$$

$$T_b = 234,845.34 \text{ N}$$

$$S_d = 0.8 * F_y$$

$$S_d = 0.8 * 250$$

$$S_d = 200.0 \text{ MPa}$$

$$A-s-r = T_b / S_d$$

$$A-s-r = 234,845.3432 / 200.0$$

$$A-s-r = 1,174.23 \text{ mm}^2$$

$$P\text{-attachment} = 3 * T_b$$

$$P\text{-attachment} = 3 * 234,845.3432$$

$$P\text{-attachment} = 704,536.03 \text{ N}$$



$$S_d\text{-shell} = (5 / 6) * F_{ty}$$

$$S_d\text{-shell} = (5 / 6) * 250.0$$

$$S_d\text{-shell} = 208.33 \text{ MPa}$$

Uplift Case 7: Frangibility Pressure

Not applicable. It is applied if the roof to shell joint is frangible.

	POBOYA 2000 TPD EXPANSION PROJECT	
(CPMWork No.) 14898	Project Doc. No.: E2602-4820-CAL-401	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

Summary of Uplift Cases

Uplift Cases	Total Uplift Load (N)	Load per Anchor (N)	Anchor Allowable Stress (MPa)	Anchor Required Area (mm ²)	Anchor Bolt Required Diameter (mm)	Attachment Design Load (N)	Allowable Shell Stress at Anchor Attachment (MPa)
Design Pressure	0	0	104.17	0.0	9.13	0.0	166.67
Test Pressure	0	0	138.89	0.0	9.13	0.0	208.33
Wind Load	0	0	200.0	0.0	9.13	0.0	208.33
Seismic Load	3,757,525.49	234,845.34	200.0	1,174.23	47.8	704,536.03	208.33
Design Pressure + Wind	0	0	138.89	0.0	9.13	0.0	208.33
Design Pressure + Seismic	3,757,525.49	234,845.34	200.0	1,174.23	47.8	704,536.03	208.33
<ul style="list-style-type: none"> Anchor Bolt Required Diameter = $\text{SQRT}((A-s-r * (4 / \pi))) + (1.22687 * p) + (Ca\text{-}anchor * 2)$ Governing Uplift Case = Seismic Load Anchor Bolt Minimum Required Area = 1,174.23 mm² 							

Bolt Required Diameter per ANSI B1.1

$d\text{-req} = \text{SQRT}((A * (4 / \pi))) + (1.22687 * n) + (Ca * 2)$
 $d\text{-req} = \text{SQRT}((1,174.2267 * (4 / \pi))) + (1.22687 * 5.0) + (1.5 * 2)$
 $d\text{-req} = 47.8 \text{ mm}$

$d \geq d\text{-req} \Rightarrow \text{PASS}$

$A\text{-s} = (\pi / 4) * ((d - (1.22687 * n))^2)$
 $A\text{-s} = (\pi / 4) * ((48 - (1.22687 * 5.0))^2)$
 $A\text{-s} = 1,376.59 \text{ mm}^2$

$Y\text{-bolt} = A\text{-s} * S_y\text{-ambient-}anchor$
 $Y\text{-bolt} = 1,376.593 * 250$
 $Y\text{-bolt} = 344,148.25 \text{ N}$

Anchorage Summary

Required Number of Anchors = 9
 Actual Number of Anchors = 16
 Bolt Hole Circle Radius = 4.35 m
 Required Bolt Diameter = 47.8 mm
 Actual Bolt Diameter = 48 mm
 Bolt Thread Pitch = 5.0 mm