

LOMBOK CFSPP FTP-2 (2X50 MW) PROJECT						Review					
								Discipline		Sign	
								Civil			
								Mechanical			
								Electrical			
								I & C			
								Support			
Log In		Date :		Comm. No :				Distribution			
A	☐ Approved										
B	☐ Approved as Note										
C	☐ Not Approved										
I	☐ Information										
APPROVAL DOES NOT RELIEVE CONTRACTOR FROM RESPONSIBILITY FOR ERRORS AND DEVIATIONS FROM CONTRACT REQUIREMENT											
By :			Date :								
Log Out		Date :		Comm. No :							
Owner : 						PT. PERUSAHAAN LISTRIK NEGARA (PERSERO) UNIT INDUK PEMBANGUNAN NUSA TENGGARA					
Engineer : 						PT. PERUSAHAAN LISTRIK NEGARA (PERSERO) PUSAT ENJINIRING KETENAGALISTRIKAN					
Contract No :											
PLN Doc No :											
Title :						WELDING REPORT FOR AREA C190					
Purpose :						ISSUE FOR APPROVAL					
Rev	Description	Prepared	Checked	Approved	Date						
0	For Approval	Benridho 	Rusnandi 	Musato 	17-April-2025						
 PT. HANAZONO ENGINEERING INDONESIA		ITEM NO									
		EQUIPMENT NAME		ESP PLATWORK FOR BOILER UNIT 2							
		PO.NO		LPP-10-F9-PO-239-R							
Contractor :		Consortium Of		Doc. No :							
 Rekind Integrated EPC and Industrial Solutions		 RAFAKO GRUPA PBG		LPP-239-MEC-VS-262-V							

DOC. NO.:
LPP-239-MEC-VS-262-V

REV

0

DATE _____

17-April-2025

BY

BR

CHKD

RSD

APVD

MRS

REVISION HISTORICAL SHEET

[illegible]

WELD & NDE CLEARANCE

Project Title : LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name : C190 CONFUSER	Report No. : HEI/QC/E2406/WNC/072
Client : PT. REKAYASA INDUSTRI	Part Name : ELEMENT 1	Date Report : November 25, 2024
Job No. : E-2406	Drawing No. : LPP-239-MEC-VG-136-V	Page No. : 1 OF 1

No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 1-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

ELEMENT 1-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

Prepared By
PT. HANAZONO ENGINEERING INDONESIA

Reviewed / Approved by :
PT. HANAZONO ENGINEERING INDONESIA

Witnessed / Reviewed by :
PT. REKAYASA INDUSTRI

Witnessed / Reviewed by :
PT. PLN (PERSERO) UIP NUSA TENGGARA

BP
BERIPR



Kusma
Nov 29. 2024

Arsy
M Arsy 18

WELD & NDE CLEARANCE

Project Title	: LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name	: C190 CONFUSER	Report No.	: HEI/QC/E2406/WNC/073
Client	: PT. REKAYASA INDUSTRI	Part Name	: ELEMENT 10	Date Report	: November 25, 2024
Job No.	: E-2406	Drawing No.	: LPP-239-MEC-VG-136-V	Page No.	: 1 OF 1

No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 10-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	175/MT/TLA/X/2024	ACC	10-Oct-24	030/TLA/RT-REK/X/2024	ACC	

ELEMENT 10-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	176/MT/TLA/X/2024	ACC	10-Oct-24	030/TLA/RT-REK/X/2024	ACC	

Prepared By
PT. HANAZONO ENGINEERING INDONESIA

Reviewed / Approved by :
PT. HANAZONO ENGINEERING INDONESIA

Witnessed / Reviewed by :
PT. REKAYASA INDUSTRI

Witnessed / Reviewed by :
PT. PLN (PERSERO) UIP NUSA TENGGARA

BPW
BERIBW



[Signature]
AN 27/11/24

[Signature]
M. Arif P I

WELD & NDE CLEARANCE

Project Title : LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name : C190 CONFUSER	Report No. : HEI/QC/E2406/WNC/074
Client : PT. REKAYASA INDUSTRI	Part Name : ELEMENT 14	Date Report : November 25, 2024
Job No. : E-2406	Drawing No. : LPP-239-MEC-VG-136-V	Page No. : 1 OF 1



No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 14-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	179/MT/TLA/X/2024	ACC	10-Oct-24	031/TLA/RT-REK/X/2024	ACC	

ELEMENT 14-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	180/MT/TLA/X/2024	ACC	10-Oct-24	031/TLA/RT-REK/X/2024	ACC	

Prepared By PT. HANAZONO ENGINEERING INDONESIA  	Reviewed / Approved by : PT. HANAZONO ENGINEERING INDONESIA  M. Arsyad P. T.	Witnessed / Reviewed by : PT. REKAYASA INDUSTRI  M. Arsyad P. T.	Witnessed / Reviewed by : PT. PLN (PERSERO) UIP NUSA TENGGARA
--	--	---	---

WELD & NDE CLEARANCE

Project Title : LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name : C190 CONFUSER	Report No. : HEI/QC/E2406/WNC/075
Client : PT. REKAYASA INDUSTRI	Part Name : ELEMENT 17	Date Report : November 25, 2024
Job No. : E-2406	Drawing No. : LPP-239-MEC-VG-136-V	Page No. : 1 OF 1


No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 17-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	185/MT/TLA/X/2024	ACC	10-Oct-24	031/TLA/RT-REK/X/2024	ACC	

ELEMENT 17-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	186/MT/TLA/X/2024	ACC	10-Oct-24	031/TLA/RT-REK/X/2024	ACC	

Prepared By PT. HANAZONO ENGINEERING INDONESIA	Reviewed / Approved by : PT. HANAZONO ENGINEERING INDONESIA	Witnessed / Reviewed by : PT. REKAYASA INDUSTRI	Witnessed / Reviewed by : PT. PLN (PERSERO) UIP NUSA TENGGARA
	 NOV 27. 2024		

WELD & NDE CLEARANCE

Project Title : LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name : C190 CONFUSER	Report No. : HEI/QC/E2406/WNC/076
Client : PT. REKAYASA INDUSTRI	Part Name : ELEMENT 2	Date Report : November 25, 2024
Job No. : E-2406	Drawing No. : LPP-239-MEC-VG-136-V	Page No. : 1 OF 1



No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 2-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

ELEMENT 2-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

Prepared By PT. HANAZONO ENGINEERING INDONESIA  	Reviewed / Approved by : PT. HANAZONO ENGINEERING INDONESIA 	Witnessed / Reviewed by : PT. REKAYASA INDUSTRI 	Witnessed / Reviewed by : PT. PLN (PERSERO) UIP NUSA TENGGARA
---	---	--	---

WELD & NDE CLEARANCE

Project Title : LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name : C190 CONFUSER	Report No. : HEI/QC/E2406/WNC/077
Client : PT. REKAYASA INDUSTRI	Part Name : ELEMENT 11	Date Report : November 25, 2024
Job No. : E-2406	Drawing No. : LPP-239-MEC-VG-136-V	Page No. : 1 OF 1

No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 11-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	177/MT/TLA/X/2024	ACC	10-Oct-24	031/TLA/RT-REK/X/2024	ACC	

ELEMENT 11-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	178/MT/TLA/X/2024	ACC	10-Oct-24	031/TLA/RT-REK/X/2024	ACC	

Prepared By
PT. HANAZONO ENGINEERING INDONESIA

Reviewed / Approved by :
PT. HANAZONO ENGINEERING INDONESIA

Witnessed / Reviewed by :
PT. REKAYASA INDUSTRI

Witnessed / Reviewed by :
PT. PLN (PERSERO) UIP NUSA TENGGARA

BP
BERKAWAN



[Signature]
NOV 27 2024

[Signature]
M. Asyiah 18

WELD & NDE CLEARANCE

Project Title	: LOMBOK CFSPF FTP-2 (2x50 MW)	Item Name	: C190 CONFUSER	Report No.	: HEI/QC/E2406/WNC/078
Client	: PT. REKAYASA INDUSTRI	Part Name	: ELEMENT 15	Date Report	: November 25, 2024
Job No.	: E-2406	Drawing No.	: LPP-239-MEC-VG-136-V	Page No.	: 1 OF 1



No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 15-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	181/MT/TLA/X/2024	ACC	10-Oct-24	032/TLA/RT-REK/X/2024	ACC	

ELEMENT 15-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	182/MT/TLA/X/2024	ACC	10-Oct-24	032/TLA/RT-REK/X/2024	ACC	

Prepared By PT. HANAZONO ENGINEERING INDONESIA 	Reviewed / Approved by : PT. HANAZONO ENGINEERING INDONESIA 	Witnessed / Reviewed by : PT. REKAYASA INDUSTRI 	Witnessed / Reviewed by : PT. PLN (PERSERO) UIP NUSA TENGGARA
---	---	--	---



WELD & NDE CLEARANCE

Project Title : LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name : C190 CONFUSER	Report No. : HEI/QC/E2406/WNC/079
Client : PT. REKAYASA INDUSTRI	Part Name : ELEMENT 16	Date Report : November 25, 2024
Job No. : E-2406	Drawing No. : LPP-239-MEC-VG-136-V	Page No. : 1 OF 1



No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 16-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	183/MT/TLA/X/2024	ACC	10-Oct-24	032/TLA/RT-REK/X/2024	ACC	

ELEMENT 16-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	184/MT/TLA/X/2024	ACC	10-Oct-24	032/TLA/RT-REK/X/2024	ACC	

Prepared By PT. HANAZONO ENGINEERING INDONESIA	Reviewed / Approved by : PT. HANAZONO ENGINEERING INDONESIA	Witnessed / Reviewed by : PT. REKAYASA INDUSTRI	Witnessed / Reviewed by : PT. PLN (PERSERO) UIP NUSA TENGGARA
 BENKIDHU	 R. Kusuma Nov 27, 2024	 M. Arsyah	 P. S.



WELD & NDE CLEARANCE

Project Title	: LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name	: C190 CONFUSER	Report No.	: HEI/QC/E2406/WNC/080
Client	: PT. REKAYASA INDUSTRI	Part Name	: ELEMENT 3	Date Report	: November 25, 2024
Job No.	: E-2406	Drawing No.	: LPP-239-MEC-VG-136-V	Page No.	: 1 OF 1



No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 3-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

ELEMENT 3-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

Prepared By PT. HANAZONO ENGINEERING INDONESIA 	Reviewed / Approved by : PT. HANAZONO ENGINEERING INDONESIA 	Witnessed / Reviewed by : PT. REKAYASA INDUSTRI 	Witnessed / Reviewed by : PT. PLN (PERSERO) UIP NUSA TENGGARA
---	---	--	---

WELD & NDE CLEARANCE

Project Title	: LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name	: C190 CONFUSER	Report No.	: HEI/QC/E2406/WNC/081
Client	: PT. REKAYASA INDUSTRI	Part Name	: ELEMENT 6	Date Report	: November 25, 2024
Job No.	: E-2406	Drawing No.	: LPP-239-MEC-VG-136-V	Page No.	: 1 OF 1



No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 6-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

ELEMENT 6-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

Prepared By PT. HANAZONO ENGINEERING INDONESIA	Reviewed / Approved by : PT. HANAZONO ENGINEERING INDONESIA	Witnessed / Reviewed by : PT. REKAYASA INDUSTRI	Witnessed / Reviewed by : PT. PLN (PERSERO) UIP NUSA TENGGARA
 BENKIDHU	 H. Hanazono MR 27. 321	 M. Arsyah	



WELD & NDE CLEARANCE

Project Title	: LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name	: C190 CONFUSER	Report No.	: HEI/QC/E2406/WNC/082
Client	: PT. REKAYASA INDUSTRI	Part Name	: ELEMENT 7	Date Report	: November 25, 2024
Job No.	: E-2406	Drawing No.	: LPP-239-MEC-VG-136-V	Page No.	: 1 OF 1

No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 7-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

ELEMENT 7-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

Prepared By PT. HANAZONO ENGINEERING INDONESIA	Reviewed / Approved by : PT. HANAZONO ENGINEERING INDONESIA	Witnessed / Reviewed by : PT. REKAYASA INDUSTRI	Witnessed / Reviewed by : PT. PLN (PERSERO) UIP NUSA TENGGARA
 BENKIDHU 	 R. R. R. 27/11/2024	 M. Arsyah	

WELD & NDE CLEARANCE

Project Title	: LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name	: C190 CONFUSER	Report No.	: HEI/QC/E2406/WNC/083
Client	: PT. REKAYASA INDUSTRI	Part Name	: ELEMENT 13	Date Report	: November 25, 2024
Job No.	: E-2406	Drawing No.	: LPP-239-MEC-VG-136-V	Page No.	: 1 OF 1



No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 13-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	10-Oct-24	028/TLA/RT-REK/X/2024	ACC	

ELEMENT 13-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	10-Oct-24	028/TLA/RT-REK/X/2024	ACC	

Prepared By PT. HANAZONO ENGINEERING INDONESIA	Reviewed / Approved by : PT. HANAZONO ENGINEERING INDONESIA	Witnessed / Reviewed by : PT. REKAYASA INDUSTRI	Witnessed / Reviewed by : PT. PLN (PERSERO) UIP NUSA TENGGARA
 B. Dhu	 J. S. M. 27.02.24	 M. Asyraf P. V.	

WELD & NDE CLEARANCE

Project Title	: LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name	: C190 CONFUSER	Report No.	: HEI/QC/E2406/WNC/084
Client	: PT. REKAYASA INDUSTRI	Part Name	: ELEMENT 8	Date Report	: November 25, 2024
Job No.	: E-2406	Drawing No.	: LPP-239-MEC-VG-136-V	Page No.	: 1 OF 1

No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 8-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	171/MT/TLA/X/2024	ACC	10-Oct-24	032/TLA/RT-REK/X/2024	ACC	

ELEMENT 8-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	172/MT/TLA/X/2024	ACC	10-Oct-24	032/TLA/RT-REK/X/2024	ACC	

Prepared By
PT. HANAZONO ENGINEERING INDONESIA

Reviewed / Approved by :
PT. HANAZONO ENGINEERING INDONESIA

Witnessed / Reviewed by :
PT. REKAYASA INDUSTRI

Witnessed / Reviewed by :
PT. PLN (PERSERO) UIP NUSA TENGGARA

BRM
BRM-bnu



Rusma
nov 27 2024

Arga
M. Arga + PR

WELD & NDE CLEARANCE

Project Title	: LOMBOK CFSPP FTP-2 (2x50 MW)	Item Name	: C190 CONFUSER	Report No.	: HEI/QC/E2406/WNC/085
Client	: PT. REKAYASA INDUSTRI	Part Name	: ELEMENT 9	Date Report	: November 25, 2024
Job No.	: E-2406	Drawing No.	: LPP-239-MEC-VG-136-V	Page No.	: 1 OF 1

No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 9-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	173/MT/TLA/X/2024	ACC	10-Oct-24	033/TLA/RT-REK/X/2024	ACC	

ELEMENT 9-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	18-Oct-24	174/MT/TLA/X/2024	ACC	10-Oct-24	033/TLA/RT-REK/X/2024	ACC	

Prepared By
PT. HANAZONO ENGINEERING INDONESIA

Reviewed / Approved by :
PT. HANAZONO ENGINEERING INDONESIA

Witnessed / Reviewed by :
PT. REKAYASA INDUSTRI

Witnessed / Reviewed by :
PT. PLN (PERSERO) UIP NUSA TENGGARA

BDI
BEN R. DIO



Yusuf
Rusli
27.2024

Arif
M. Arif

WELD & NDE CLEARANCE

Project Title	: LOMBOK CFSP FTP-2 (2x50 MW)	Item Name	: C190 CONFUSER	Report No.	: HEI/QC/E2406/WNC/086
Client	: PT. REKAYASA INDUSTRI	Part Name	: ELEMENT 12	Date Report	: November 25, 2024
Job No.	: E-2406	Drawing No.	: LPP-239-MEC-VG-136-V	Page No.	: 1 OF 1

No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
					Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result	

ELEMENT 12-1

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	AF-1307	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

ELEMENT 12-2

1	JT-01	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
3	JT-03	HEI-WPS-AWS-FC-001	FCAW	SR-0904	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
4	JT-04	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
5	JT-05	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	
6	JT-06	HEI-WPS-AWS-FC-001	FCAW	JH-1006	22-Oct-24	LPP-239-MEC-VR-019-V	ACC	-	-	-	-	-	-	

Prepared By
PT. HANAZONO ENGINEERING INDONESIA

Reviewed / Approved by :
PT. HANAZONO ENGINEERING INDONESIA

Witnessed / Reviewed by :
PT. REKAYASA INDUSTRI

Witnessed / Reviewed by :
PT. PLN (PERSERO) UIP NUSA TENGGARA

BDP
BENEFIT



Rusma
27. 2024

M. Arif & P.P.