

LOMBOK CFSPP FTP-2 (2X50 MW) PROJECT CONTRACTOR DOCUMENT REVIEW		Review	Discipline	Sign	
			Civil		
			Mechanical		
			Electrical		
			I & C		
			Support		
Log In	Date : Comm. No :	Distribution	Contractor Record		
A	☐ Approved		Working Document		
B	☐ Approved as Note				
C	☐ Not Approved				
I	☐ Information				
APPROVAL DOES NOT RELIEVE CONTRACTOR FROM RESPONSIBILITY FOR ERRORS AND DEVIATIONS FROM CONTRACT REQUIREMENT					
By :	Date :				
Log Out	Date : Comm. No :				
Owner :			PT. PERUSAHAAN LISTRIK NEGARA (PERSERO) UNIT INDUK PEMBANGUNAN NUSA TENGGARA		
Engineer :			PT. PERUSAHAAN LISTRIK NEGARA (PERSERO) PUSAT ENJINIRING KETENAGALISTRIKAN		
Contract No :					
PLN Doc No :					
Title :		WELDING REPORT FOR AREA C420			
Purpose :		ISSUE FOR APPROVAL			
Rev	Description	Prepared	Checked	Approved	Date
0	For Approval	Benridho 	Rusnandi 	Musato 	17-April-2025
 PT. HANAZONO ENGINEERING INDONESIA We are always partner with you		ITEM NO			
		EQUIPMENT NAME		ESP PLATWORK FOR BOILER UNIT 2	
		PO.NO		LPP-10-F9-PO-239-R	
Contractor :		Consortium Of		Doc. No :	
 Rekind Integrated EPC and Industrial Solutions RAFAKO GRUPA PBG				LPP-239-MEC-VS-282-V	

DOC. NO.:
LPP-239-MEC-VS-282-V

0

APVD
MRS

[illegible]



PT. HANAZONO Engineering Indonesia The quality partner we need							WELD & NDE CLEARANCE							
Project Title : LOMBOK CFSPP FTP-2 (2x50 MW)						Item Name : C420 GAS DISTRIBUTION IN CONFUSER				Report No. : HEI/QC/E2406/WNC/090				
Client : PT. REKAYASA INDUSTRI						Part Name : C420				Date Report : November 25, 2024				
Job No. : E-2406						Drawing No. : LPP-239-MEC-VG-151-V				Page No. : 1 OF 1				
No.	Joint No.	WPS No.	Weld Process	ID Welder	Visual Inspection Report			MT Inspection Report			RT Inspection Report			Remarks
Date	Report No.	Result	Date	Report No.	Result	Date	Report No.	Result						
DEVICE 2-1														
1	JT-01	HEI-WPS-AWS-FC-001	FCAW	AF-1307	04-Dec-24	LPP-239-MEC-VR-022-V	ACC	18-Nov-24	259/MT/TLA/XI/2024	ACC	-	-	-	
2	JT-02	HEI-WPS-AWS-FC-001	FCAW	RM-1206	04-Dec-24	LPP-239-MEC-VR-022-V	ACC	-	-	-	-	-	-	
Prepared By PT. HANAZONO ENGINEERING INDONESIA			Reviewed / Approved by : PT. HANAZONO ENGINEERING INDONESIA				Witnessed / Reviewed by : PT. REKAYASA INDUSTRI				Witnessed / Reviewed by : PT. PLN (PERSERO) UIP NUSA TENGGARA			
 BPRM														

Witnessed / Reviewed by :
PT. PLN (PERSERO) UIP NUSA TENGGARA

Resmi
10/11/2024

m. Arrogant p. 4