



## OBJECT



Strength Calculation for Tailing Thickener Overflow  
 Poboya 2000tpd Expansion Project  
 Client Doc Number: [HNZ-V-PT0061.08-4840-STR-CAL-001](#)

## REFERENCES

3655.15-61.08-4000-F-BOD-001 Process Design Criteria  
 3655.15-61.08-4000-F-CAL-001 Mass Balance


B	Issued for Approval	08/05/2026	Wawan	Ardiyanto	Murasato	
A	Issued for Review	15/04/2026	Wawan	Ardiyanto	Murasato	
Revision	Description	Date	Prepared By	Reviewed By	Approved	Client App
CLIENT PT Citra Palu Mineral		TITLE Strength Calculation for Tailing Thickener Overflow				REV B
PROJECT Poboya 2000tpd Expansion Project		PT. COMO ENGINEERS		PROJECT No. E2602		
BY Wawan	DATE 08/05/2026	CHECKED Ardiyanto	DATE 08/05/2026	Doc No E2602-4840-CAL-101		



	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 3 of 19

## CONTENTS

Description	Page
1. Introduction.....	4
2. Support Document .....	4
3. Code and Reference .....	4
4. Design .....	4
5. Conclusion .....	19
6. Anchor Bolt Design .....	20

<b>COMO</b> ENGINEERS	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	 PT Citra Paha Minerals
(CPMWork No.) 14898	Project Doc. No.: E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 4 of 19

## 1. Introduction

This document consist of additional analysis for tailing overflow tank shell thickness. The dimension is 4.5 m height and 7 m for the diameter. Additional analysis needed to calculate the strength of shell tank to resist walkway platform load that located on top of the tank.

## 2. Support Document

- 3665.15-61.08-4840-M-DWG-001 - GA - Thickener Overflow Tank

## 3. Code and Reference


Code and reference that used for this calculation listed below :

- API STD 650 2018 – Wloded Tanks for Oil Storage
- SNI 1729:2020 – Spesifikasi untuk Bangunan Gedung Baja Struktural

## 4. Design

### 4.1 Isometric Model



Analysis design for the tank use STAAD Pro software. Tank model picture showed below :



Material			
PLATE			
Shell elev. (m)	Main Thickness (mm)	Corrosion Allowance (mm)	Design Thickness (mm)
Bottom Plate	7	3	10
0 - 4.5	5	3	8
STIFFENER			
Profile elev. (m)	Type		
1.65	L.130.130.12		
3.45	L.130.130.12		
4.5	L.200.200.25		
PLATFORM SUPPORT			
Profile elev. (m)	Type		
4.5	Half Tee. 300.300.10.15		

Picture 1. Tank Model and Properties



	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 5 of 19


## 4.2 Load and Combination

### 4.2.1 Daad Load

Unit weight of steel used as calculation is 78.5 kN/m<sup>3</sup>.

### 4.2.2 Hidrostatic Load

Hidrostatic load is pressure load from fluida content. Specific gravity fluida is 1.11 Ton/m<sup>3</sup>



Hidrostatic load :  $1.11 \times 4.995 = 48.98 \text{ Ton/m}^2 \rightarrow \text{kN/m}^2$

### 4.2.3 Walkway Platform Load

#### GRATING

$$q = 0.45 \text{ kN/m}^2$$

$$\text{Tributary 1} = 1 \text{ m}$$

$$\text{Tributary 2} = 0.5 \text{ m}$$

$$\text{Input load 1} = 0.45 \text{ kN/m}$$

$$\text{Input load 2} = 0.225 \text{ kN/m}$$

#### LIVE LOAD

$$q = 5 \text{ kN/m}^2$$


$$\text{Tributary 1} = 1 \text{ m}$$


$$\text{Tributary 2} = 0.5 \text{ m}$$

$$\text{Input load} := 5 \text{ kN/m}$$

$$\text{Input load} := 2.5 \text{ kN/m}$$



<b>COMO</b> ENGINEERS	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	 PT Citra Palu Minerals
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 6 of 19



Picture 2. Walkway Input Load

#### 4.2.4 Seismic Load

Seismic load calculated based on API 650.

- The seismic overturning moment at the base of the tank shell shall be the SRSS summation of the impulsive and convective components multiplied by the respective moment arms to the center of action of the forces unless otherwise specified.

Ringwall Moment,  $M_{rw}$ :

$$M_{rw} = \sqrt{[A_i(W_i X_i + W_s X_s + W_r X_r)]^2 + [A_c(W_c X_c)]^2} \quad (\text{E.6.1.5-1})$$

#### Equation Ai :

Impulsive spectral acceleration parameter,  $A_i$ :



$$A_i = S_{DS} \left( \frac{I}{R_{wi}} \right) = 2.5 Q F_a S_0 \left( \frac{I}{R_{wi}} \right) \quad (\text{E.4.6.1-1})$$

$$\text{However, } A_i \geq 0.007 \quad (\text{E.4.6.1-2})$$

and, for  $S_1 \geq 0.6$ :

$$A_i \geq 0.5 S_1 \left( \frac{I}{R_{wi}} \right) = 0.625 S_p \left( \frac{I}{R_{wi}} \right) \quad (\text{E.4.6.1-3})$$



	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 7 of 19

$$I = 1 \text{ (category II)}$$

$$S_d = 0.806$$

$$R_{wi} = 3.5$$

**Table E.4—Response Modification Factors for ASD Methods**

Anchorage system	$R_{wi}$ (impulsive)	$R_{wc}$ (convective)
Self-anchored	3.5	2
Mechanically-anchored	4	2

$$A_i = 0.23$$

### **Equation Ac**

**Convective spectral acceleration parameter,  $A_c$ :**

$$\text{When, } T_C \leq T_L \quad A_c = K S_{D1} \left( \frac{1}{T_c} \right) \left( \frac{I}{R_{wc}} \right) = 2.5 K Q F_a S_0 \left( \frac{T_s}{T_c} \right) \left( \frac{I}{R_{wc}} \right) \leq A_i \quad (\text{E.4.6.1-4})$$

$$\text{When, } T_C > T_L \quad A_c = K S_{D1} \left( \frac{T_L}{T_c^2} \right) \left( \frac{I}{R_{wc}} \right) = 2.5 K Q F_a S_0 \left( \frac{T_s T_L}{T_c^2} \right) \left( \frac{I}{R_{wc}} \right) \leq A_i \quad (\text{E.4.6.1-5})$$

$$K_s = 0.58$$

$$T_c = 3.03$$



$$R_{wc} = 2$$

$$K = 1.5$$

$$S_{D1} = 0.582$$

$$A_c = 0.14$$



	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 8 of 19

### Equation Wi and Xi :

#### **E.6.1.1 Effective Weight of Product**

The effective weights  $W_i$  and  $W_c$  shall be determined by multiplying the total product weight,  $W_p$ , by the ratios  $W_i/W_p$  and  $W_c/W_p$ , respectively, Equations E.6.1.1-1 through E.6.1.1-3.

When  $D/H$  is greater than or equal to 1.333, the effective impulsive weight is defined in Equation E.6.1.1-1:

$$W_i = \frac{\tanh\left(0.866\frac{D}{H}\right)}{0.866\frac{D}{H}} W_p \quad (\text{E.6.1.1-1})$$

When  $D/H$  is less than 1.333, the effective impulsive weight is defined in Equation E.6.1.1-2:

$$W_i = \left[1.0 - 0.218\frac{D}{H}\right] W_p \quad (\text{E.6.1.1-2})$$

When  $D/H$  is greater than or equal to 1.3333, the height  $X_i$  is determined by Equation E.6.1.2.1-1:

$$X_i = 0.375H \quad (\text{E.6.1.2.1-1})$$



When  $D/H$  is less than 1.3333, the height  $X_i$  is determined by Equation E.6.1.2.1-2:

$$X_i = \left[0.5 - 0.094\frac{D}{H}\right] H \quad (\text{E.6.1.2.1-2})$$

D	=	7 m
H	=	4.5 m
D/H	=	1.56
Y	=	1.82
Wp	=	3093.24 kN
perimeter	=	22.00 m
3.67H/D	=	2.36
Wi	=	2005.43 kN
Xi	=	1.69 m





	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 9 of 19

### Equation Wc and Xc :

The effective convective weight is defined in Equation E.6.1.1-3:

$$W_c = 0.230 \frac{D}{H} \tanh\left(\frac{3.67H}{D}\right) W_p \quad (\text{E.6.1.1-3})$$

The height  $X_c$  is determined by Equation E.6.1.2.1-3:

$$X_c = \left[ 1.0 - \frac{\cosh\left(\frac{3.67H}{D}\right) - 1}{\frac{3.67H}{D} \sinh\left(\frac{3.67H}{D}\right)} \right] H \quad (\text{E.6.1.2.1-3})$$

$$W_c = 1087.11 \text{ kN}$$

$$X_c = 2.92 \text{ m}$$

Value of Ws and Xs :

Ws = Total weight of tank shell and appurtenances

Xs = Height from bottom of the tank shell to the shell's center of gravity

L.130.130.12

$$A = 2976 \text{ mm}^2 = 0.002976 \text{ m}^2$$

$$w = 5.14 \text{ kN}$$

$$n = 2$$

$$\text{Weight Total L.130} = 10.28 \text{ kN}$$

L.200.200.25

$$A = 9375 \text{ mm}^2 = 0.009375 \text{ m}^2$$

$$w = 16.19 \text{ kN}$$

$$n = 1$$

$$\text{Weight Total L.130} = 16.19 \text{ kN}$$

H.300.300.15.10 H.Tee



$$A = 11850 \text{ mm}^2 = 0.01185 \text{ m}^2$$

$$w = 1.53 \text{ kN}$$

$$n = 4$$

$$\text{Weight Total L.130} = 6.14 \text{ kN}$$



	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 10 of 19

Shell T 10 mm

$$\begin{aligned}
 A &= 0.22 \text{ m}^2 \\
 w &= 31.09 \text{ kN}
 \end{aligned}$$

Shell T 8 mm

$$\begin{aligned}
 A &= 0.22 \text{ m}^2 \\
 w &= 46.63 \text{ kN}
 \end{aligned}$$



$$\begin{aligned}
 \text{TOTAL WEIGHT (Ws)} &= 110.32 \text{ kN} \\
 X_s &= 2.25 \text{ m}
 \end{aligned}$$

From calculation above,

$$\begin{aligned}
 (A_i \cdot W_i) / \text{perimeter} &= 20.99 \text{ kN/m, at H} = 1.69 \text{ m} \\
 (A_i \cdot W_s) / \text{perimeter} &= 1.15 \text{ kN/m, at H} = 2.25 \text{ m} \\
 (A_c \cdot W_c) / \text{perimeter} &= 7.77 \text{ kN/m, at H} = 2.92 \text{ m}
 \end{aligned}$$

For simplification :

$$\begin{aligned}
 W &= 29.91 \text{ kN/m} \\
 H &= 2.03 \text{ m}
 \end{aligned}$$

	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 11 of 19

#### 4.2.5 Wind Load

Wind load calculated based on SNI 1727 : 2020.

#### 4.2.6 Load Combination

Load combination based on SNI 1729 : 2020



Service load combination :

1.  $D$
2.  $D + L$
3.  $D + (L_r \text{ atau } R)$
4.  $D + 0,75 L + 0,75(L_r \text{ atau } R)$
5.  $D + 0,6 W$
6.  $D + 0,75 (0,6 W) + 0,75 L + 0,75 (L_r \text{ atau } R)$
7.  $0,6D + 0,6 W$
  
8.  $1,0D + 0,7E_v + 0,7E_h$
9.  $1,0D + 0,525E_v + 0,525E_h + 0,75L$
10.  $0,6D - 0,7E_v + 0,7E_h$

Ultimate load combination :

1.  $1,4D$
2.  $1,2 D + 1,6 L + 0,5 (L_r \text{ atau } R)$
3.  $1,2D + 1,6 (L_r \text{ atau } R) + (L \text{ atau } 0,5 W)$
4.  $1,2D + 1,0 W + L + 0,5(L_r \text{ atau } R)$
5.  $0,9 D + 1,0 W$
  
6.  $1,2D + E_v + E_h + L$
7.  $0,9D - E_v + E_h$




	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 12 of 19


### 4.3 Analysis Design



#### 4.3.1 Input Model

##### a. Hidrostatic Load (MAX =80.34 kN/m<sup>2</sup>)




##### b. Walkway Platform Load






	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 13 of 19

c. Seismic Load ( $W_i = 29.91 \text{ kN/m}$ )




d. Wind Load ( $0.6 \text{ kN/m}^2$ )




	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 14 of 19

#### 4.3.2 Output Data






**Stress Shell due Selfweight (max : 1.22 MPa)**




**Stress Shell due Platform Support (max : 3.1 MPa)**





	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 15 of 19




**Stress Shell due Seismic Load EQx (max : 35 MPa)**



**Stress due Windload Wx+ (max : 1 MPa)**

	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 16 of 19





Stress due Load Combination (Service) (max : 70.5 MPa)


Stress Summary Table

	Plate	L/C	Shear (Local)		Membrane (Local)			Bending Moment (Local)		
			SQX MPa	SQY MPa	SX MPa	SY MPa	SXY MPa	MX kN-m/m	MY kN-m/m	MXy kN-m/m
Max Qx	400	19 201	0.259	0.003	-0.411	0.447	8.497	0	0	-0.07
Min Qx	382	19 201	-0.259	-0.003	0.399	-0.49	-8.771	0	0	0.07
Max Qy	403	20 202	-0.006	0.142	18.419	-0.18	0.113	0.011	0.006	-0.002
Min Qy	385	20 202	0.006	-0.142	-18.386	0.137	0.16	-0.011	-0.006	0.002
Max Sx	403	24 206	-0.004	0.101	39.427	0.454	0.538	0.01	0.01	-0.002
Min Sx	385	20 202	0.006	-0.142	-18.386	0.137	0.16	-0.011	-0.006	0.002
Max Sy	39	24 206	0	-0.008	24.936	4.583	0.846	0	0.001	0
Min Sy	268	18 103	0	0	-0.33	-7.609	3.725	0	0	0
Max Sxy	43	24 206	-0.002	-0.008	15.462	-3.049	14.214	0	0	0
Min Sxy	51	24 206	0.003	-0.009	15.006	-4.551	-14.05	0	0	0
Max Mx	276	20 202	0.004	-0.011	0.27	-0.816	0.218	0.018	0.009	-0.008
Min Mx	275	22 204	0.004	0.011	0.27	-0.816	-0.218	-0.018	-0.009	-0.008
Max My	405	23 205	0.028	0.097	38.763	-0.488	1.611	0.011	0.01	0.013
Min My	275	22 204	0.004	0.011	0.27	-0.816	-0.218	-0.018	-0.009	-0.008
Max Mxy	399	19 201	0.202	-0.004	-0.502	0.37	-0.091	0	0	0.086
Min Mxy	381	19 201	-0.202	0.004	0.535	-0.413	-0.182	0	0	-0.086





	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 17 of 19


**Maximum stress Sx occurred due combination load 206 : 1.0DL + 0.525 EQ + 0.75LL + 0.75Hidrostatic**




**Stress due Combination 103 (max : 41.8 MPa)**

	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 18 of 19


All Stress ratio stiffener frame condition are under allowance (1) :





<b>COMO</b> ENGINEERS	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	 PT Citra Palu Minerals
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 19 of 19

## 5. Conclusion

- All component, steel frame and steel shell with current configuration is capable to resist the loads.
- The configuration as follows :



Material			
PLATE			
Shell elev. (m)	Main Thickness (mm)	Corrosion Allowance (mm)	Design Thickness (mm)
Bottom Plate	7	3	10
0 - 1.8	5	3	8
1.8 - 4.5	5	3	8
STIFFENER			
Profile elev. (m)	Type		
1.65	L.130.130.12		
3.45	L.130.130.12		
4.5	L.200.200.25		
PLATFORM SUPPORT			
Profile elev. (m)	Type		
4.5	Half Tee. 300.300.10.15		

	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	Page 20

## Anchor Bolt Design

A-s = Installed Bolt Nominal Root Area (mm<sup>2</sup>)

A-s-r = Anchor Required Root Area (mm<sup>2</sup>)

Av = Seismic Vertical Earthquake Acceleration Coefficient (g)

Ca-anchor = Anchor Corrosion Allowance (mm)

D = Tank nominal diameter (m)

Dac = Bolt Circle Diameter (m)

Fp = Design Pressure Operating Ratio

Fty = Minimum Yield Strength of the Bottom Shell Course (MPa)

Fy = Anchor Yield Strength per API-650 Table 5.21a (MPa)

Fy-ambient = Anchor Yield Strength at Ambient Temperature per API-650 Table 5.21a (MPa)

H = Tank Height (m)

MWS = Shell Wind Overturning Moment (N.m)

Ma-anchor = Anchor Material

Mrw = Seismic Overturning Moment (N.m)

N = Anchors Quantity

N-min = Minimum Required Number of Anchors per API-650 5.12.3

OD = Tank Outer diameter (m)

P = Internal Pressure (kPa)

P-attachment = Anchor Attachment Design Load per API-650 5.12.13 and Steel Plate Engineering Data-Volume 2 Part V (N)

PWR = Roof Wind Pressure (kPa)

Pt = Test Pressure (kPa)

Sd = Allowable Anchor Stress per API-650 Table 5.21a (MPa)

Sd-shell = Allowable Shell Stress at Anchor Attachment per API-650 Table 5.21a (MPa)

Tb = Load per Anchor per API-650 5.12.2 (N)

U = Net Uplift Load per API-650 5.12.2 (N)

W1 = Corroded Weight of the Roof Plates Plus the Corroded Weight of the Shell and any Other Corroded Permanent Attachments Acting on the Shell (N)

W2 = Corroded Weight of the Shell and any Corroded Permanent Attachments Acting on the Shell Including the Portion of the Roof Plates and Framing Acting on The Shell (N)

W3 = Nominal Weight of the Roof Plates Plus the Nominal Weight of the Shell and any Other Permanent Attachments Acting on the Shell (N)

Wr-pl = Roof Plates Nominal Weight (N)

Wr-pl-corr = Roof Corroded Plates Weight (N)

Wrs-pl-corr = Roof Plates Corroded Weight Acting on The Shell (N)

Ws-framing = Shell New Framing Weight (stiffeners) (N)

Ws-framing-corr = Shell Corroded Framing Weight (stiffeners) (N)

Ws-pl = Shell Plates Nominal Weight (N)

Ws-pl-corr = Shell Corroded Plates Weight (N)

Wss = Roof Structure Nominal Weight Acting on The Shell (N)

Wss-corr = Roof Structure Corroded Weight Acting on The Shell (N)

Y-bolt = Anchor Yield Load (N)



d = Anchor Bolt Diameter (mm)

d-req = Bolt Required Diameter per ANSI B1.1 (mm)

p = Bolt Thread Pitch (mm)

position\_angles = Anchors Position Angles (deg)



	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

$A_v = 0.38 \text{ g}$   
 $C_a\text{-anchor} = 1.5 \text{ mm}$   
 $D = 7.0 \text{ m}$   
 $D_{ac} = 7.18 \text{ m}$   
 $F_p = 0.4$   
 $F_{ty} = 250.0 \text{ MPa}$   
 $H = 4.5 \text{ m}$   
 $MWS = 22,094.37 \text{ N.m}$   
 $Ma\text{-anchor} = A307-B$   
 $Mrw = 552,412.65 \text{ N.m}$   
 $N = 12$   
 $OD = 7.02 \text{ m}$   
 $P = 0.0 \text{ kPa}$   
 $PWR = 0 \text{ kPa}$   
 $P_t = 0.0 \text{ kPa}$   
 $W_{r-pl} = 0.0 \text{ N}$   
 $W_{r-pl-corr} = 0.0 \text{ N}$   
 $W_{rs-pl-corr} = 0 \text{ N}$   
 $W_{s-framing} = 8,123.97 \text{ N}$   
 $W_{s-framing-corr} = 5,520.52 \text{ N}$   
 $W_{s-pl} = 60,937.3 \text{ N}$   
 $W_{s-pl-corr} = 38,085.81 \text{ N}$   
 $W_{ss} = 21,458.49 \text{ N}$   
 $W_{ss-corr} = 0.0 \text{ N}$   
 $d = 27 \text{ mm}$   
 $p = 3.0 \text{ mm}$   
 $position\_angles = [0 \ 30 \ 60 \ 90 \ 120 \ 150 \ 180 \ 210 \ 240 \ 270 \ 300 \ 330] \text{ deg}$

#### **Anchors Spacing Requirements**

##### **Max Allowable Spacing Between Anchors at Shell Outer Diameter per API-650 5.12.3**

Max Allowable Spacing ( $max\_allowable\_spacing$ ) = 3 m

Actual Spacing ( $actual\_spacing$ ) = 1.84 m

$actual\_spacing \leq max\_allowable\_spacing \Rightarrow PASS$

$N_{min} = CEILING(((\pi * OD) / 3))$

$N_{min} = CEILING(((\pi * 7.016) / 3))$

$N_{min} = 8$

$N \geq N_{min} \Rightarrow PASS$



Anchors meet spacing requirements.

##### **Anchors Average Spacing (half the span on each side of the anchor) at Bolt Circle**

Anchors are equally spaced.

Average Spacing ( $average\_spacing$ ) = 1.88 m

Bolt loads will be based on equally spaced anchors.

	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

#### Anchor Material Properties

Material (A307-B) = A307-B

Minimum Tensile Strength (Sut-anchor) = 415 MPa

Minimum Yield Strength (Sy-anchor) = 250 MPa

Minimum Yield Strength at Ambient Temperature (Sy-ambient-anchor) = 250 MPa

$F_y = \text{MIN}(\text{Sy-ambient-anchor}, 380)$

$F_y = \text{MIN}(250, 380)$

$F_y = 250 \text{ MPa}$

$F_{y\text{-ambient}} = \text{MIN}(\text{Sy-ambient-anchor}, 380)$

$F_{y\text{-ambient}} = \text{MIN}(250, 380)$

$F_{y\text{-ambient}} = 250 \text{ MPa}$

#### Uplift Load Cases per API-650 Table 5.21a

$W1 = W_{s\text{-pl-corr}} + W_{s\text{-framing-corr}} + W_{r\text{-pl-corr}}$

$W1 = 38,085.8123 + 5,520.5153 + 0.0$

$W1 = 43,606.33 \text{ N}$

$W2 = W_{s\text{-pl-corr}} + W_{s\text{-framing-corr}} + W_{rs\text{-pl-corr}} + W_{ss\text{-corr}}$

$W2 = 38,085.8123 + 5,520.5153 + 0 + 0.0$

$W2 = 43,606.33 \text{ N}$

$W3 = W_{s\text{-pl}} + W_{s\text{-framing}} + W_{r\text{-pl}} + W_{ss}$

$W3 = 60,937.2996 + 8,123.9667 + 0.0 + 21,458.4928$

$W3 = 90,519.76 \text{ N}$

#### Uplift Case 1: Design Pressure Only

$U = (P * (D^2) * 785) - W1$

$U = (0.0 * (7.0^2) * 785) - 43,606.3275$

$U = -43,606.33 \text{ (Set to } 0 \text{ N since it cannot be less than } 0)$

$T_b = U / N$

$T_b = 0 / 12$

$T_b = 0 \text{ N}$

$S_d = (5 / 12) * F_y$

$S_d = (5 / 12) * 250$

$S_d = 104.17 \text{ MPa}$

$A\text{-s-r} = T_b / S_d$

$A\text{-s-r} = 0 / 104.1667$



$A\text{-s-r} = 0.0 \text{ mm}^2$

$P\text{-attachment} = 1.5 * T_b$

$P\text{-attachment} = 1.5 * 0$

$P\text{-attachment} = 0.0 \text{ N}$



	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

$Sd-shell = (2 / 3) * Fty$   
 $Sd-shell = (2 / 3) * 250.0$   
 $Sd-shell = 166.67 \text{ MPa}$

#### **Uplift Case 2: Test Pressure Only**

$U = (Pt * (D^2) * 785) - W3$   
 $U = (0.0 * (7.0^2) * 785) - 90,519.7592$   
 $U = -90,519.76 \text{ (Set to 0 N since it cannot be less than 0)}$

$Tb = U / N$   
 $Tb = 0 / 12$   
 $Tb = 0 \text{ N}$

$Sd = (5 / 9) * Fy\text{-ambient}$   
 $Sd = (5 / 9) * 250$   
 $Sd = 138.89 \text{ MPa}$

$A-s-r = Tb / Sd$   
 $A-s-r = 0 / 138.8889$   
 $A-s-r = 0.0 \text{ mm}^2$

$P\text{-attachment} = 1.5 * Tb$   
 $P\text{-attachment} = 1.5 * 0$   
 $P\text{-attachment} = 0.0 \text{ N}$

$Sd-shell = (5 / 6) * Fty$   
 $Sd-shell = (5 / 6) * 250.0$   
 $Sd-shell = 208.33 \text{ MPa}$



#### **Uplift Case 3: Wind Load Only**

$U = ((PWR * (D^2) * 785) + ((4 * MWS) / D)) - W2$   
 $U = ((0 * (7.0^2) * 785) + ((4 * 22,094.3692) / 7.0)) - 43,606.3275$   
 $U = -30,980.97 \text{ (Set to 0 N since it cannot be less than 0)}$

$Tb = U / N$   
 $Tb = 0 / 12$   
 $Tb = 0 \text{ N}$

$Sd = 0.8 * Fy$   
 $Sd = 0.8 * 250$   
 $Sd = 200.0 \text{ MPa}$

$A-s-r = Tb / Sd$   
 $A-s-r = 0 / 200.0$   
 $A-s-r = 0.0 \text{ mm}^2$

	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

$P\text{-attachment} = 1.5 * T_b$

$P\text{-attachment} = 1.5 * 0$

$P\text{-attachment} = 0.0 \text{ N}$

$S_d\text{-shell} = (5 / 6) * F_{ty}$

$S_d\text{-shell} = (5 / 6) * 250.0$

$S_d\text{-shell} = 208.33 \text{ MPa}$

#### **Uplift Case 4: Seismic Load Only**

$U = ((4 * Mr_w) / D) - (W_2 * (1 - (0.4 * A_v)))$

$U = ((4 * 552,412.6546) / 7.0) - (43,606.3275 * (1 - (0.4 * 0.3808)))$

$U = 278,700.16 \text{ N}$

$T_b = U / N$

$T_b = 278,700.1623 / 12$

$T_b = 23,225.01 \text{ N}$

$S_d = 0.8 * F_y$

$S_d = 0.8 * 250$

$S_d = 200.0 \text{ MPa}$

$A\text{-s-r} = T_b / S_d$

$A\text{-s-r} = 23,225.0135 / 200.0$

$A\text{-s-r} = 116.13 \text{ mm}^2$

$P\text{-attachment} = 3 * T_b$

$P\text{-attachment} = 3 * 23,225.0135$

$P\text{-attachment} = 69,675.04 \text{ N}$

$S_d\text{-shell} = (5 / 6) * F_{ty}$

$S_d\text{-shell} = (5 / 6) * 250.0$

$S_d\text{-shell} = 208.33 \text{ MPa}$

#### **Uplift Case 5: Design Pressure + Wind Load**

$U = (((F_p * P) + PWR) * (D^2) * 785) + ((4 * MWS) / D) - W_1$

$U = (((0.4 * 0.0) + 0) * (7.0^2) * 785) + ((4 * 22,094.3692) / 7.0) - 43,606.3275$

$U = -30,980.97 \text{ (Set to } 0 \text{ N since it cannot be less than } 0)$

$T_b = U / N$

$T_b = 0 / 12$



$T_b = 0 \text{ N}$

$S_d = (5 / 9) * F_y$

$S_d = (5 / 9) * 250$

$S_d = 138.89 \text{ MPa}$



	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

$$A-s-r = T_b / S_d$$

$$A-s-r = 0 / 138.8889$$

$$A-s-r = 0.0 \text{ mm}^2$$

$$P\text{-attachment} = 1.5 * T_b$$

$$P\text{-attachment} = 1.5 * 0$$

$$P\text{-attachment} = 0.0 \text{ N}$$

$$S_d\text{-shell} = (5 / 6) * F_{ty}$$

$$S_d\text{-shell} = (5 / 6) * 250.0$$

$$S_d\text{-shell} = 208.33 \text{ MPa}$$

#### Uplift Case 6: Design Pressure + Seismic Load

$$U = ((F_p * P * (D^2) * 785) + ((4 * M_{rw}) / D)) - (W_1 * (1 - (0.4 * A_v)))$$

$$U = ((0.4 * 0.0 * (7.0^2) * 785) + ((4 * 552,412.6546) / 7.0)) - (43,606.3275 * (1 - (0.4 * 0.3808)))$$

$$U = 278,700.16 \text{ N}$$

$$T_b = U / N$$

$$T_b = 278,700.1623 / 12$$

$$T_b = 23,225.01 \text{ N}$$

$$S_d = 0.8 * F_y$$

$$S_d = 0.8 * 250$$

$$S_d = 200.0 \text{ MPa}$$

$$A-s-r = T_b / S_d$$

$$A-s-r = 23,225.0135 / 200.0$$

$$A-s-r = 116.13 \text{ mm}^2$$

$$P\text{-attachment} = 3 * T_b$$

$$P\text{-attachment} = 3 * 23,225.0135$$

$$P\text{-attachment} = 69,675.04 \text{ N}$$



$$S_d\text{-shell} = (5 / 6) * F_{ty}$$

$$S_d\text{-shell} = (5 / 6) * 250.0$$

$$S_d\text{-shell} = 208.33 \text{ MPa}$$

#### Uplift Case 7: Frangibility Pressure

Not applicable. It is applied if the roof to shell joint is frangible.

	<b>POBOYA 2000 TPD EXPANSION PROJECT</b>	
(CPMWork No.) 14898	Project Doc. No. : E2602-4840-CAL-101	Revision No. : B
(Vendor Work No.) E2602	Purchase Order No. : 14898	

#### Summary of Uplift Cases

Uplift Cases	Total Uplift Load (N)	Load per Anchor (N)	Anchor Allowable Stress (MPa)	Anchor Required Area (mm <sup>2</sup> )	Anchor Bolt Required Diameter (mm)	Attachment Design Load (N)	Allowable Shell Stress at Anchor Attachment (MPa)
Design Pressure	0	0	104.17	0.0	6.68	0.0	166.67
Test Pressure	0	0	138.89	0.0	6.68	0.0	208.33
Wind Load	0	0	200.0	0.0	6.68	0.0	208.33
Seismic Load	278,700.16	23,225.01	200.0	116.13	18.84	69,675.04	208.33
Design Pressure + Wind	0	0	138.89	0.0	6.68	0.0	208.33
Design Pressure + Seismic	278,700.16	23,225.01	200.0	116.13	18.84	69,675.04	208.33
<ul style="list-style-type: none"> <li>Anchor Bolt Required Diameter = <math>\text{SQRT}((A-s-r * (4 / \pi))) + (1.22687 * p) + (Ca\text{-}anchor * 2)</math></li> <li>Governing Uplift Case = Seismic Load</li> <li>Anchor Bolt Minimum Required Area = 116.13 mm<sup>2</sup></li> </ul>							

#### Bolt Required Diameter per ANSI B1.1

$d\text{-req} = \text{SQRT}((A * (4 / \pi))) + (1.22687 * n) + (Ca * 2)$   
 $d\text{-req} = \text{SQRT}((116.1251 * (4 / \pi))) + (1.22687 * 3.0) + (1.5 * 2)$   
 $d\text{-req} = 18.84 \text{ mm}$

$d \geq d\text{-req} \Rightarrow \text{PASS}$

$A\text{-s} = (\pi / 4) * ((d - (1.22687 * n))^2)$   
 $A\text{-s} = (\pi / 4) * ((27 - (1.22687 * 3.0))^2)$   
 $A\text{-s} = 427.09 \text{ mm}^2$

$Y\text{-bolt} = A\text{-s} * S_y\text{-ambient-anchor}$   
 $Y\text{-bolt} = 427.0948 * 250$   
 $Y\text{-bolt} = 106,773.69 \text{ N}$

#### Anchorage Summary

Required Number of Anchors = 8  
 Actual Number of Anchors = 12  
 Bolt Hole Circle Radius = 3.59 m  
 Required Bolt Diameter = 18.84 mm  
 Actual Bolt Diameter = 27 mm  
 Bolt Thread Pitch = 3.0 mm